

## Pool/Spa Daily Log

Year: \_\_\_\_\_

Pool Name: \_\_\_\_\_

Pool Volume: \_\_\_\_\_

CPO: \_\_\_\_\_

Phone: \_\_\_\_\_

Max Bather Load: \_\_\_\_\_

Date(MM/DD)	Time	Disinfectant (ppm)		pH	Water Temperature	Flow Gauge (gpm)	# of Bathers Observed	Water Condition (Clear, Turbid, Green Etc.)	Total Alkalinity	Cyanuric Acid	Calcium Hardness	Additional Comments <i>(Include quantities of chemicals and filter aid used, filter washing, cleaning and disinfecting of pool decks and dressing rooms, fecal release events and pool closures)</i>	Initials	SVRS FUNCTIONALITY TEST		Oxidation Reduction Potential (ORP) Controller Calibration Test			
		Free	Total											Testing of SVRS systems: must be performed as directed by the manufacturer. Failure to perform the test weekly invalidates the SVRS system as complying with 392-302-18(4)		Date:			
																<u>N/A</u>	<u>N/A</u>		
															<u>PASS</u>	<u>N/A</u>			
															<u>FAIL</u>				<u>PASS</u>
																<u>N/A</u>	<u>FAIL</u>		
																<u>PASS</u>			<u>FAIL</u>
																<u>FAIL</u>	(Recalibrate ORP system as soon as possible after failure of a calibration test. Perform Testing a minimum of 4 times daily until the ORP system is properly calibrated)		
																<b>REQUIRED MONTHLY</b> R392-302-27(5)			
																<b>Total Coliform</b>		<b>Heterotrophic Plate Count</b>	
																<b>Date:</b>		<b>Date:</b>	
																<b>Pass</b>	<b>Fail</b>	<b>Pass</b>	<b>Fail</b>
																Failure follow-up date:		Failure follow-up date:	